

2018 YILI AĞUSTOS AYI ARITMA DENEY RAPORU

Standart	RENK	BULANIKLIK	PH	SICAKLIK	ILETKENLIK	ÇOKSÜJEN	ALÜMİNYUM	ARSENİK	KADMIYUM	KROM	BAKIR	DEMİR	MANGAN	KURŞUN	NİKEL	BOR	ANTİMON	SELENYUM	FLORÜR	KLORÜR	NİTRİT	NİTRAT	SÜLFAT	SODYUM	AMONYUM	MAGNEZYUM	ALSİYUM	S.KLOR	TOPLAM KOLFÖR KOLFÖR																						
EC			6.5-9.5	°C	2500µS/cm		0.2 mg/l	10 µg/l	5.0 µg/l	50 µg/l	2000 µg/l	0.2 mg/l	50 µg/l	10 µg/l	20 µg/l	1 mg/l	5 µg/l	10 µg/l	0.2 mg/l	250 mg/l	0.5 mg/l	50 mg/l	250 mg/l	200 mg/l	0.5 mg/l	mg/l	mg/l	0.5 mg/l	0																						
WHO	15		6.5-8.5	°C	2500µS/cm		0.2 mg/l	10 µg/l	5.0 µg/l	50 µg/l	2000 µg/l	0.2 mg/l	50 µg/l	10 µg/l	20 µg/l	1 mg/l	5 µg/l	10 µg/l	0.2 mg/l	250 mg/l	0.5 mg/l	45 mg/l	250 mg/l	200 mg/l	0.5 mg/l	mg/l	mg/l	0.5 mg/l	0																						
EPA	15		6.5-8.5	°C	2500µS/cm		0.2 mg/l	10 µg/l	5.0 µg/l	50 µg/l	2000 µg/l	0.3 mg/l	50 µg/l	10 µg/l	20 µg/l	1 mg/l	5 µg/l	10 µg/l	0.2 mg/l	250 mg/l	0.5 mg/l	45 mg/l	250 mg/l	200 mg/l	0.5 mg/l	mg/l	mg/l	0.5 mg/l	0																						
TSİ	20		6.5-9.5	°C	2500µS/cm	Min. 5 mg/l	0.2 mg/l	10 µg/l	5.0 µg/l	50 µg/l	2000 µg/l	0.2 mg/l	50 µg/l	10 µg/l	20 µg/l	1 mg/l	5 µg/l	10 µg/l	0.2 mg/l	250 mg/l	0.5 mg/l	50 mg/l	250 mg/l	200 mg/l	0.5 mg/l	mg/l	mg/l	0.5 mg/l	0																						
1.08.2018	9	1	1.92	0.64	7.23	8.24	19.5	20.1	224	275	5.0	7.3	<0.02	0.02	<0.31	<0.37	<2	<2	<2	<2	0.04	0.04	29.5	30.0	<0.004	<0.004	<0.33	<0.33	4.98	18.0	22.3	22.5	<0.008	<0.008	3.85	3.96	22.4	0.78	0	0											
2.08.2018	12	1	1.84	0.6	5.98	7.98	19.6	19.6	226	284	5.3	7	0.04	0.05	<0.31	<0.37	<2	<2	<2	<2	0.04	0.05	28.2	29.7	<0.004	<0.004	<0.33	<0.33	5.00	18.2	22.0	22.6	<0.008	<0.008	3.83	3.95	22.3	0.72	0	0											
3.08.2018	22	1	2.51	0.70	7.34	8.27	20.6	19.4	224	283	5.2	7.3	0.05	0.04	<0.34	<0.34	<2	<2	<2	<2	0.04	0.04	28.1	29.9	<0.004	<0.004	<0.33	<0.33	7.97	18.1	22.2	22.7	<0.008	<0.008	3.82	3.92	22.1	0.95	0	0											
4.08.2018	16	1	1.91	0.48	7.38	8.05	20.3	19.1	223	301	5.3	7.3	0.03	0.03	<0.34	<0.34	<2	<2	<2	<2	0.04	0.03	29.2	29.8	<0.004	<0.004	<0.33	<0.33	6.04	19.3	22.2	24.1	<0.008	<0.008	4.06	4.18	24.6	0.62	0	0											
5.08.2018	18	1	1.18	0.23	7.19	8.22	18.9	19.4	222	296	5.2	7.2	0.02	0.03	<0.34	<0.34	<2	<2	<2	<2	0.04	0.03	29.1	29.9	<0.004	<0.004	<0.33	<0.33	6.07	18.1	22.3	24.3	<0.008	<0.008	3.95	4.15	24.3	0.86	0	0											
6.08.2018	16	1	2.1	0.34	7.57	7.97	20.7	20.8	224	300	4.9	7.1	0.05	0.04	<0.34	<0.34	<2	<2	<2	<2	0.04	0.04	27.8	29.3	<0.004	<0.004	<0.33	<0.33	5.34	31.7	21.2	21.5	0.07	<0.008	3.78	3.92	29.1	1.02	0	0											
7.08.2018	13	1	2.67	0.92	7.3	8.48	21.3	19.8	226	293	1.8	7.1	0.07	0.06	<0.34	<0.34	<2	<2	<2	<2	0.10	0.04	27.7	29.1	<0.004	<0.004	<0.33	<0.33	5.4	31.8	21	21.4	0.08	<0.008	3.75	3.9	28.8	0.84	0	0											
8.08.2018	21	1	2.63	0.98	7.28	8.33	19.8	20	226	294	2.4	7.2	0.06	0.09	<0.34	<0.34	<2	<2	<2	<2	0.08	0.05	27.9	29.3	<0.004	<0.004	<0.33	<0.33	5.37	32	21.1	21.4	0.08	<0.008	3.76	3.94	29.7	0.79	0	0											
9.08.2018	15	1	2.11	0.66	7.26	8.17	19.4	19.4	222	312	4.1	7.1	0.04	0.02	<0.34	<0.34	<2	<2	<2	<2	0.09	0.05	28	29.5	<0.004	<0.004	<0.33	<0.33	5.33	31.6	21.3	21.7	0.08	<0.008	3.79	3.99	29	1.02	0	0											
10.08.2018	13	1	2.46	0.60	7.45	8.05	20.7	19	226	302	3.9	7.1	0.06	0.03	<0.34	<0.34	<2	<2	<2	<2	0.09	0.04	27.6	29.2	<0.004	<0.004	<0.33	<0.33	5.35	31.6	21.2	21.5	0.08	<0.008	3.75	3.98	29.1	1.13	0	0											
11.08.2018	6	1	2.03	0.41	7.45	8.13	20.1	19.4	224	280	3.9	7.1	0.04	<0.02	<0.34	<0.34	<2	<2	<2	<2	0.15	<0.01	33	1.9	<0.34	<0.34	<2	<2	<2	<2	0.08	0.04	27.2	29	<0.004	<0.004	<0.33	<0.33	5.31	31.2	21	21.3	0.08	<0.008	3.72	3.96	29.2	1	0	0	
12.08.2018	7	1	2.11	0.17	7.43	8.01	20	19.6	224	279	4.1	6.9	0.06	0.03	<0.34	<0.34	<2	<2	<2	<2	0.2	<0.01	67.6	2.87	<0.34	<0.34	<2	<2	<2	<2	0.08	0.05	27.7	28.9	<0.004	<0.004	<0.33	<0.33	5.41	31.6	21.7	23.4	0.08	<0.008	3.81	3.96	22.9	1.11	0	0	
13.08.2018	9	1	2.77	0.80	7.53	8.28	20.6	19.7	221	276	4.0	7.1	0.09	0.02	<0.34	<0.34	<2	<2	<2	<2	0.33	<0.01	24.1	2.02	<0.34	<0.34	<2	<2	<2	<2	0.08	0.05	27.5	28.7	<0.004	<0.004	<0.33	<0.33	5.44	31.4	21.6	23.3	0.07	<0.008	3.77	3.95	22.7	0.94	0	0	
14.08.2018	24	1	2.28	0.74	7.48	8.26	19.5	19.3	226	280	4.0	7.2	0.06	0.03	<0.34	<0.34	<2	<2	<2	<2	0.35	<0.01	17.1	3.95	<0.34	<0.34	<2	<2	<2	<2	0.08	0.05	27.5	28.8	<0.004	<0.004	<0.33	<0.33	5.42	31.5	21.3	23.6	0.07	<0.008	3.75	3.99	23.1	1.07	0	0	
15.08.2018	25	1	2.76	1.44	7.35	8.11	19.2	19.8	227	277	4	7.2	0.08	0.03	<0.34	<0.34	<2	<2	<2	<2	0.38	<0.01	21.1	2.68	<0.34	<0.34	<2	<2	<2	<2	0.08	0.04	27.4	28.5	<0.004	<0.004	<0.33	<0.33	5.45	31.7	21.1	23.5	0.08	<0.008	3.72	3.98	23.3	0.92	0	0	
16.08.2018	21	1	3.26	0.18	7.26	8.13	19.3	18.9	223	277	3.9	7.3	0.12	0.05	<0.34	<0.34	<2	<2	<2	<2	0.70	<0.01	74.0	3.9	<0.34	<0.34	<2	<2	<2	<2	0.08	0.04	28.8	31.1	<0.004	<0.004	<0.33	<0.33	5.26	27.8	22	26	0.03	<0.008	3.83	4.11	26.7	0.98	0	0	
17.08.2018	12	1	3.03	0.85	7.48	8.57	20.4	19.4	222	274	4.0	7.3	0.09	0.03	<0.34	<0.34	<2	<2	<2	<2	0.23	<0.01	26.3	1.39	<0.34	<0.34	<2	<2	<2	<2	0.07	0.05	28.3	30.5	<0.004	<0.004	<0.33	<0.33	5.6	28.3	22.5	22.8	<0.008	<0.008	3.97	4.16	26.6	1.07	0	0	
18.08.2018	10	1	2.86	1.37	7.38	8.35	19.5	19.3	223	278	4.2	7.4	0.03	<0.02	<0.34	<0.34	<2	<2	<2	<2	0.16	<0.01	21.6	2.67	<0.34	<0.34	<2	<2	<2	<2	0.07	0.04	27.9	28.9	<0.004	<0.004	<0.33	<0.33	4.90	24.5	21.4	22.5	<0.008	<0.008	<0.008	4.15	4.23	24.7	1.21	0	0
19.08.2018	5	1	2.55	1.36	7.35	8.34	20.3	20.1	222	274	4.1	7.4	0.02	<0.02	<0.37	<0.37	<2	<2	<2	<2	0.38	0.02	26.7	13.5	<0.34	<0.34	<2	<2	<2	<2	0.12	0.05	28.3	30.3	<0.004	0.03	<0.33	<0.33	5.3	25.6	22.5	22.6	<0.008	<0.008	<0.008	4.01	4.18	26.3	1.04	0	0
20.08.2018	14	1	2.57	0.8	7.2	8.4	18.4	20	240	269	4.2	7.1	0.02	<0.02	<0.34	<0.34	<2	<2	<2	<2	0.05	<0.01	59.6	6.78	<0.34	<0.34	<2	<2	<2	<2	0.07	0.03	27.4	28.7	<0.004	<0.004	<0.33	<0.33	5.6	31.6	21.2	22.5	<0.008	<0.008	3.75	3.98	23	1.04	0	0	
21.08.2018	11	1	2.30	0.95	7.31	8.32	19.3	18.7	221	281	4.2	7.3	0.04	0.04	<0.34	<0.34	<2	<2	<2	<2	0.21	0.02	17.7	8.80	<0.34	<0.34	<2	<2	<2	<2	0.10	0.08	29.2	31.5	<0.004	<0.004	<0.33	<0.33	6.04	24.5	22.5	22.9	0.15	<0.008	3.91	4.15	26.7	0.77	0	0	
22.08.2018	9	1	1.88	0.97	7.33	8.4	19.7	18.9	224	277	4.1	7.4	0.05	0.05	<0.34	<0.34	<2	<2	<2	<2	0.14	0.01	36.3	7.9	<0.34	<0.34	<2	<2	<2	<2	0.10	0.04	28.8	30.8	<0.004	<0.004	<0.33	<0.33	5.53	23.6	22.3	22.7	0.04	<0.008	4.02	4.23	24.7	0.93	0	0	
23.08.2018	6	1	1.78	0.61	7.42	8.22	20	18.7	224	291	4.4	7.4	0.05	0.04	<0.34	<0.34	<2	<2	<2	<2	0.17	0.01	13.7	6.84	<0.34	<0.34	<2	&lt																							